

1ST NOTICE OF VIOLATION

October 27, 2022

Brenda K Marcum
7784 Pontius Rd
Groveport, OH 43125

RE: **7784 Pontius Rd, Madison Township**
Tax District #180 Parcel #004959

Dear Ms. Marcum:

Franklin County Public Health had inspected the home sewage treatment system located at the above-referenced address on **May 12, 2022**. Please see enclosed report.

A follow-up investigation of the aeration treatment system was conducted on **October 17, 2022**, confirming continued use of an unapproved aerator motor. The Ohio Administrative Code 3701-29-13 (P) states, in part: **"Devices critical to the performance of pretreatment components shall be maintained as manufacturer's original equipment matching the system configuration approved by the director."**

After-market aeration motors sold online claiming to be "Alternative Compatible Replacement" or "Alternative Compatible Motor" do not meet the highlighted regulation above. Equipment must only be replaced with original APPROVED type.

You will be given until **November 30, 2022**, to replace your aerator motor with the approved Norweco motor to prevent referral to the Franklin County Board of Health for further legal action.

Please feel free to contact this office if you have any questions. Your anticipated cooperation in this matter will be highly appreciated.

Sincerely,



Rich Stewart, MPH, REHS
Franklin County Public Health, Water Quality Program
RichardStewart@franklincountyohio.gov
614-398-6311

cc: Madison Township Trustees