



FRANKLIN COUNTY PUBLIC HEALTH
 280 E BROAD ST
 COLUMBUS, OH 43215
 1-614-525-3160
 www.myfcph.org

Aerobic Treatment System Observation Report

Water Quality and IDDE Programs

Off-Lot Record # 3528	Political Subdivision PRAIRIE TWP	<input checked="" type="checkbox"/> 1st Observation <input type="checkbox"/> 2nd Observation <input type="checkbox"/> Additional Observation
Property Address 1010 ALTON DARBY CREEK RD GALLOWAY, OH 43119		Location of System on the Property <input checked="" type="checkbox"/> Front <input type="checkbox"/> Side <input type="checkbox"/> Rear
Property Owner SALAMONY, MICHAEL Eric + Kortney Fleharty		Owner's Phone # 1-614-878-6539
Owner's Address 6655 FEDER ROAD 1010 Alton Darby		City/State/Zip GALLOWAY, OH 43119

System Description

System Manufacturer <input checked="" type="checkbox"/> Jet <input type="checkbox"/> Norweco <input type="checkbox"/> Multi-Flo <input type="checkbox"/> Aqua-Clear <input type="checkbox"/> Nayadic <input type="checkbox"/> Oldham <input type="checkbox"/> Other	
Inspection Box Present <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Discharge Point <input checked="" type="checkbox"/> Storm Sewer <input type="checkbox"/> Road Ditch <input type="checkbox"/> Watercourse <input type="checkbox"/> Field Tile <input type="checkbox"/> Undetermined <input type="checkbox"/> Other

Observations

Motor <input type="checkbox"/> Missing Motor/Component <input type="checkbox"/> Mechanical Failure <input type="checkbox"/> Electrical Failure <input type="checkbox"/> Visible Damage
Aeration Chamber (Tank) <input type="checkbox"/> Sewage Odor <input type="checkbox"/> Floating Solids <input type="checkbox"/> High Liquid Level <input type="checkbox"/> Inadequate Aeration
Effluent <input type="checkbox"/> Sewage Odor <input type="checkbox"/> Gray Color <input type="checkbox"/> Black Color <input type="checkbox"/> Solids Present
Filter <input type="checkbox"/> Gray Liquid <input type="checkbox"/> Black Liquid <input type="checkbox"/> Solids Present
Blockage in the System <input type="checkbox"/> Blockage observed at _____
Additional Observations <input checked="" type="checkbox"/> you have an after-market motor that is not approved by Ohio Dept. of Health. Needs to be Jet.

Action

<input type="checkbox"/> No corrective action necessary at the time of this observation. Thank you.		
<input checked="" type="checkbox"/> Franklin County Public Health staff will return in <u>30</u> days to observe the system operation. Please refer to the items checked in the Observation section of this form. Please call the number listed below when repairs are completed.		
<input checked="" type="checkbox"/> The observations noted above will be referred to a Registered Sanitarian for further administrative enforcement pursuant to Ohio Administrative Code 3701-29 and/or Ohio Revised Code 3718.		
Franklin County Public Health Staff Alyssa Lute	Phone # (614) 525-034 0365	Date 11/14/2023



1ST NOTICE OF VIOLATION

January 5, 2023

Eric & Kortney Fleharty
1010 Alton Darby Creek Rd
Galloway, OH 43119

RE: **1010 Alton Darby Creek Rd**
Tax District #241 Parcel #000157

Dear Eric & Kortney Fleharty:

Franklin County Public Health had inspected the home sewage treatment system located at the above-referenced address on **November 13, 2022**. Please see enclosed report.

A follow-up investigation of the aeration treatment system was conducted on **January 5, 2023**, confirming continued use of an unapproved aerator motor. The Ohio Administrative Code 3701-29-13 (P) states, in part: "Devices critical to the performance of pretreatment components shall be maintained as manufacturer's original equipment matching the system configuration approved by the director."

After-market aeration motors sold online claiming to be "Alternative Compatible Replacement" or "Alternative Compatible Motor" do not meet the highlighted regulation above. Equipment must only be replaced with original APPROVED type. Please replace with Jet aerator motor.

You will be given until **February 8, 2023**, to replace your aerator motor with the approved Jet motor to prevent referral to the Franklin County Board of Health for further legal action.

Please feel free to contact this office if you have any questions. Your anticipated cooperation in this matter will be highly appreciated.

Sincerely,

A handwritten signature in black ink, appearing to read "Rich Stewart".

Rich Stewart, MPH, REHS
Franklin County Public Health, Water Quality Program
RichardStewart@franklincountyohio.gov
614-398-6311

cc: Jackson Township Trustees