

Franklin County Public Health 280 East Broad Street Columbus, Ohio 43215-4562 (614) 525-3160 www.myfcph.org

Aerobic Treatment System Observation Report

Water Quality and IDDE Programs

Public Health		
	Political Subdivision Prairie TWP	√ 1st Observation □ 2nd Observation □ Additional Observation
Property Address	Rd Galloway	Location of System on the Property □ Front □ Side MARear
		Owner's Phone #
Owner's Address (04) Alton Rd		City/State/Zip Galloway, OH 43119
System Description		
System Manufacturer □ Jet b Norweco □ Multi-Flo □ Aqua-Clear □ Nayadic □ Oldham □ Other		
Inspection Box Present Yes XNO		
Observations		
Motor □ Missing Motor/Component □ Mechanical Failure □ Electrical Failure □ Visible Damage		
Aeration Chamber (Tank) □ Sewage Odor □ Floating Solids □ High Liquid Level □ Inadequate Aeration		
Effluent □ Sewage Odor □ Gray Color □ Black Color □ Solids Present		
Filter Gray Liquid Black Liquid Solids Present		
Blockage in the System □ Blockage observed at		
Additional Observations: Of you have an after-market motor that is		
not approved by Ohio Dept. of Health Needs to be		
Action Norweco.		
□ No corrective action necessary at the time of this observation. Thank you.		
Franklin County Public Health staff will return indays to observe the system operation. Please refer to the items checked in the Observation section of this form. Please call the number listed below when repairs are completed.		
The observations noted above will be referred to a Registered Sanitarian for further administrative enforcement pursuant to Ohio Administrative Code 3701-29 and/or Ohio Revised Code 3718.		
Franklin County Public Healt		hone# Date
anyso	Wo oth	614/15251-634 036 11/14/2002



280 East Broad Street · Columbus, Ohio · 43215-4562

1ST NOTICE OF VIOLATION

January 6, 2023

Jeffrey A Denney 641 Alton Rd Galloway, OH 43119

RE:

641 Alton Rd

Tax District #240 Parcel #002176

Dear Jeffrey A Denney:

Franklin County Public Health had inspected the home sewage treatment system located at the above-referenced address on **November 14**, **2022**.

A follow-up investigation of the aeration treatment system was conducted on **January 6**, **2023**, confirming continued use of an unapproved aerator motor. The <u>Ohio Administrative Code 3701-29-13 (P)</u> states, in part: "Devices critical to the performance of pretreatment components shall be maintained as manufacturer's original equipment matching the system configuration approved by the director."

After-market aeration motors sold online claiming to be "Alternative Compatible Replacement" or "Alternative Compatible Motor" do not meet the highlighted regulation above. Equipment must only be replaced with original APPROVED type. Please replace with Norweco aerator motor.

You will be given until **February 13, 2023**, to replace your after-market aerator motor with the approved Norweco motor to prevent referral to the Franklin County Board of Health for further legal action.

Please feel free to contact this office if you have any questions. Your anticipated cooperation in this matter will be highly appreciated.

Sincerely,

Rich Stewart, MPH, REHS

Franklin County Public Health, Water Quality Program

RichardStewart@franklincountyohio.gov

614-398-6311

CC:

Prairie Township Trustees